



UNITED BRASS WORKS, INC.
 714 S. Main St. Randleman, N.C. 27317
 Tel: 800-334-3035 Fax: 800-498-4696 www.ubw.com




Model 903 1/2" High Pressure Lower Gauge Fixture Valve With Ball Checks

250WSP @ 406° F

ASME Compliant per B31.1 and
 Section one, PG 60 Appendix A18
 Of ASME Boiler Code
 CRN OCO7135.2C

**Contains Lead. Not Intended for Use
 In Potable Water Systems**



MATERIAL LIST

No.	Description	Material
1	Body	CDA 836
2	S.S. Ball	302 S.S.
3	O-Ring	EPDM
4	Union Tail Piece	CDA 360
5	Union Nut	CDA 922
6	Stem	CDA 693
7	Bonnet	CDA 360
8	Packing	33 NAFG
9	Packing Nut	CDA 360
10	Hand Wheel	Zinc
11	Marker Disc	Aluminum
12	Brass Nut	Brass
13	Seal Washer	FKM
14	Washer	Steel (Plated)
15	O-Ring	EP 70 Durometer
16	Rod Bracket	300 Series S.S.
17	Glass Nut	CDA 360
18	Model 380MXFSP 1/2"	CDA 836

Unit Weight 2.8 lbs.