



UNITED BRASS WORKS, INC.
 714 S. Main St. Randleman, N.C. 27317
 Tel: 800-334-3035 Fax: 800-498-4696 www.ubw.com





Model 902 1/2" High Pressure Upper Gauge Fixture Valve With Ball Check

250WSP @ 406° F

**ASME Compliant per B31.1 and
Section One, PG 60 Appendix A18
of ASME Boiler Code
CRN OCO7135.2C**

*** Contains Lead. Not Intended for Use
in Potable Water Systems ***



MATERIAL LIST		
No.	Description	Material
1	Body	CDA 836
2	SS Ball	302 SS
3	Retaining Ring	300 Series SS
4	O-Ring	EPDM
5	Union Tail Piece	CDA 360
6	Union Nut	CDA 922
7	Stem	CDA 693
8	Bonnet	CDA 360
9	Packing	33NAGF
10	Packing Nut	CDA 360
11	Hand Wheel	Zinc
12	Marker Disc	Aluminum
13	Brass nut	Brass
14	Seal Washer	FKM
15	Washer	Steel (Plated)
16	O-Ring	Buna
17	Rod Bracket	Stainless Steel
18	Glass Nut	CDA 360
19	Pipe Plug	CDA 360

Unit Weight 2.9 lbs.